



Partial Discharge Report

Report Name
Date and Time 2024-10-15
13:56:52
Site Name
Site Location
Performed By
Phone
Email

Statistics

Total Images 1
Floating 1



Partial Discharge Info

Max. Level	15.9 dB
Discharge Level	Severe
Selected Frequency Range	22.0 ~ 32.0 kHz
Distance	3.0 m


Image Information

Created	2024-04-25 15:31:30
File Name	Floating-实拍
Device Model	AI76
Device Serial No.	EA1315083


Discharge Type

Corona	7%
Particle	0%
Surface	0%
Floating	92%


PRPD



Signal



FFT



Text Note