



Partial Discharge Report

Report Name
Date and Time 2024-10-15
13:54:37
Site Name
Site Location
Performed By
Phone
Email

Statistics

Total Images 1
Surface 1



Partial Discharge Info

Max. Level	29.2 dB
Discharge Level	Moderate
Selected Frequency Range	24.1 ~ 45.9 kHz
Distance	3.0 m


Image Information

Created	2024-04-25 15:26:11
File Name	Surface-实拍
Device Model	AI76
Device Serial No.	EA1315083


Discharge Type

Corona	1%
Particle	0%
Surface	98%
Floating	0%


PRPD



Signal



FFT



Text Note